

Waaxda Ka Hortaga Dabka ee Seattle

220 3rd Avenue South

Seattle, WA 98104-2608 Iimaylka: permits@seattle.gov



Teendhooyin iyo Kuleyliyeyaasha loogu talagalay Cuntada Dibada lagu qaato iyo Hawlaха: Tilmaamaha Badqabka iyo Ruqsada SFD v12272024

Teendhooyinku waxay noqon karaan khatar haddii uu dab qabsado ama soo dhacaan. Sababtan awgeed, teendhooyinka waaweyn waxaa xakameeya Xeerarka Dabka iyo Dhismaha. Kuleyliyeyaasha sidoo kale waxay keeni karaan khataro, haddii kuleylku uu bixiyo propane/Liquefied Petroleum Gas (LPG), naaftada, ama korontada. Dhukumiintigani waxa uu soo bandhigayaa soo koobida shuruudaha xeerka iyo sidoo kale habka loo habeeyey ruqsad bixinta ee gaarka ah iyo xeerarka la dhaqan galiyay inta lagu jiro aafada COVID iyo soo kabashada.

TEENDHOOYIN

Waxaad u baahan tahay Ruqsada Seattle Fire Department (SFD) si aad u isticmaasho teendho ku meel gaar ah, dabool, ama qaab dhismeed hawo taageerto haddii:

- Qaab-dhismeedku wuxuu ka weyn yahay 400 fiit oo isku wareeg ah wuxuuna leeyahay hal ama in ka badan oo darbiga ah; AMA,
- Qaab-dhismeedku wuxuu ka weyn yahay 700 fiit oo isku wareeg ah oo aan lahayn darbiga (shiraaca saqaf ah kaliya).
- Waxaad haysataa laba ama in ka badan oo yaryar oo teendho ah oo saqafka keliya ah kuwaas oo la dhigay geeska in ka yar 12 cagood oo isu geyntoodu ka weyn tahay 700 fiit oo isku wareeg ah.

Ruqsada waxaa ku jira shuruudo ay tahay inaad raacdoo ku saabsan alaabta teendhada iyo rakibida si aad ugu hoggaansanto shuruudaha badqabka ee xeerka dabka. Ruqsadu waxay shaqaynaysaa 28 maalmood. Haddii teendhadaadu la kulanto ama dhaafto xadka cabbirka sare oo la isticmaali doono in ka badan 28 maalmood, ka dib markaad hesho ogolaanshaha teendhada ku meel gaadhka ah ee SFD, waxaad kala xiriiri kartaa ruqsada Seattle Department of Construction and Inspections 206-684-8850. Shiraacyada ayaa sidoo kale u baahan ogolaansho SDCI mana maamusho SFD.

Hubi in Teendhadaada uu Ansixi karo Maareeyaha Dab-demiska Haddii aad iibsanyaso teendho ka weyn 400 fiit oo laba jibaaran, fadlan hubi inay buuxisay heerarka dib u celinta ololka ee xeerka dabka (eeg xaaladda ruqsada #8 ee bogga ugu dambeeyaa). Waxaa lagaaga baahan doonaa inaad aqbasho mas'uuliyada iyo mas'uuliyada rakibitaanka saxda ah ee teendhada heerarkii warshadaha iyo/ama tilmaamaha rakibida soo saaraha. Teendhooyinka ku meel-gaarka ah waa in aan la degin xiliyada barafka ama barafku urursan yihiin ilaa loogu talagalay in si buuxda loo raro qaab-dhismeed sida Xeerka Dhismaha Seattle. Teendhooyin yaryar waa in la saaraa inta lagu jiro ururinta barafka dhulka fariista iyo barafka iyo dhacdooyinka dabayshu. Teendhooyinka laga kireeyo shirkad kiro teendho ah oo sumcad leh waxay buuxin doontaa heerarka xeerka dabka oo shirkadda teendhadu waxay qaadan doontaa mas'uuliyadda rakibida habboon.

Miyaan doortaa Teendho Darbi la'aan ah? Sababaha hawo-qaadishada, inta lagu jiro cudurka faafa, xayiraadaha dawladda ayaa mararka qaarkood u baahday eber, hal, laba ama ka badan darbi ah. Waxaa laga yaabaa inaad u baahato inaad midan tixgeliso markaad iibsanyaso ama kiraynayso teendho, maadaama aan la garanayn in kala duwanaanshaha mustaqbalka ay sababi doonaan soo noqoshada xayiraadahaas.

Intaa waxa dheer, waxa kale oo jira saamaynta xeerka dabka ee doorashada teendho leh ama aan lahayn darbiyo: Haddii teendhadaadu aysan lahayn darbiyo, waxaad u baahan tahay kaliya ruqsada SFD haddii teendhadaadu ka weyn tahay 700 fiit oo isku wareeg ah, ama aad leedahay teendhooyin isku garab yaala oo isaga 12 fiit oo guud ahaan ka badan 700 fiit oo isku wareeg ah. Si kastaba ha noqotee, haddii aad darbiyo ku darto teendhadaada, teendhooyinka yaryar waxay u baahan doonaan ruqsada SFD sidoo kale. Haddii teendhadaadu leedahay darbiyo, ruqsad ayaa looga baahan yahay teendhooyinka ah 400 fiit isku wareeg ah ama ka weyn.

Teendhooyin iyo Kuleyliyeysaasha loogu talagalay Cuntada Dibada lagu qaato iyo Hawlaha: Tilmaamaha Badqabka iyo Ruqsada SFD

Intee in u jirta Dhisme ayaa Teendho laga Dhisi karaa? Tusaale ahaan, Teendhooyinka Geesaha Miisaska Cuntada SFD
guud ahaan waxay u baahan tahay dib u dhigid inta u dhaxaysa teendhooyinka iyo dhismayaasha ugu yaraan 12 fiit.

Waa maxay Shuruudaha Ruqsada Buuxa ee Teendhada Ku meel-gaarka ah? Fadlan ka eeg bogga u dambeeyaa.

KULAYLINTA IYO NAL GALINTA BANAAKA

Propane (LPG) iyo kuleyliyeysaasha naaftada ku shaqeeya waxay u baahan yihiin ruqsad Taangiyada Shidaadka looma Ogola Gudaha Teendhada Tani waxay la macno tahay kuleyliyaha "maashruumka" waxaa loo ogol yahay meel 10 fiit u jirta teendhooyinka, laakiin waa ka mamnuuc teendhooyinka dhexdooda. Kuleyliyeysaasha qaabka "Maas-cagalayda" u samaysan ee hawo ku afuufa teendhada hoosteeda dibadda waa la oggol yahay waxaana badanaa laga helaa shirkadaha kiraynta teendhada. Taangiga shidaalka waa in ugu yaraan 10 fiit u jirta teendhada lagana baxo waana inaad haysataa 3A 40BC dab-damis.

Haddii aad kiraysato LPG/propane ama kuleyliyaha naaftada shirkad kireysta teendho, shirkadaas badanaa waxay yeelan doontaa ogolaanshaha kuleyliyaha propane/naaftada SFD ee loo baahan yahay, uma baahnid ogolaansho dheeri ah. Waa inay sidoo kale bixiyaan dab-damisyada loo baahan yahay. Haddii aad iibsanyaso kuleyliyeysaasha LPG/propane ama naaftada, waxaad u baahan doontaa ruqsada SFD.

SFD waxay soo saartaa ruqsad kuleylka Propane/LPG ku meel-gaarka ah (koodhka ruqsada 8207) iyo ogolaanshaha naaftada (koodhka ruqsada 1102) si loo daboolo baahiyahaaga kululaynta ee kala duwan.

Kuleyliyeysaasha korontada iyo Nalalka waa la ogol yahay dibadda iyo sidoo kale gudaha teendhada oo uma baahna oggolaansho gaar ah SFD. Si kastaba ha ahaatee, waa in lagu xiriiriya meel koronto oo la ogol yahay.

Wixii macluumaad dheeraad ah, fadlan kala xiriir Waaxda Ruqsada SFD permits@seattle.gov. Adeegyo tarjumaad ayaa diyaar ah. Fadlan haka waabin inaad la hadasho qof ku hadla luqadaada - kaliya noo sheeg luqadda iyo lambarka taleefankaaga.

SHURUUDAH RUQSADA RUQSADAHA TEENDHOYINKA KU MEEL-GAARKA AH EE SFD

1. Balac ahaan 12-fiit "CLEAR AREA" waa inuu ku yaal hareeraha teendhada oo dhan. Waa inaan gaari la dhiganin 20 fiit u jira teendhada. (Cabirka teendhada waxaa kamid ah saamiga loo isticmaalo in lagu taageero dhismaha. "CLEAR AREA" waa in lagu cabbiraa banaanka cabirka ugu fog.) Shuruudaha masaafu waxaa laga yaabaa in laga dhaafu ama uu wax ka badalo wakiilka SFD marka qaab-dhismeedka sawirkha uu yahay arin xadidaysa, dhaafitaanka waxaa lagu xusi karaa qorshaha ku lifaaqan ogolaanshaha. Goobta shuruudaha oggolaanshaha ay kiciyan laba ama in ka badan oo teendho yaryar oo saqafka-keliya ah kuwaas oo la dhigay dhinac dhinac in ka yar 12 fiit isu jirana guud ahaan goobtooda ka weyn yahay 700 fiit oo laba jibaaran, "CLEAR AREA" waxay khusaysaa booska banaan ee u dhexeeyaa kooxaha la oggol yahay teendhooyin saqafka kaliya. (21 SFC Qaybaha 3103.8.1, 3103.8.2 & 3103.8.6)
2. 20 fiit balac ahaan "FIRE DEPT. ACCESS LANE" waa in la bixiyaa si loo galoo dhismaha teendhada. (21 SFC Qaybta 503.2.1)
3. Tirada ugu yar iyo ballaca dariiqooyinka iridaha/ka baxitaanka waa inay ahaadaan sida ku qoran shaxda hoose. Masaafada ugu badan ee safarka laga baxo waa 100 fiit marka gudaha teendhada. (21 SFC Section 3103.12)

Culayska Qofka Degan	# iradaha ugu yar	Balac irid kasta ee u yar
10 ilaa 199	2	72
200 ilaa 499	3	72
500 ilaa 999	4	96

Teendhooyin iyo Kuleyliyeasha loogu talagalay Cuntada Dibada lagu qaato iyo Hawlaha: Tilmaamaha Badqabka iyo Ruqsada SFD

1.000 ilaa 1.999	5	120
2.000 ilaa 2.999	6	120
Ka badan 3,000	7	120

4. Ka bixitaan kasta waa inay leedahay calaamad iftiin leh oo 'EXIT' ah oo leh xarfo ugu yaraan 5 inji ah dherer ahaan. (21 SFC Section 3103.12.6, 1013.6.1).
5. Lahaada hal dab-damis oo lagu qiimeeyay ugu yaraan 2A 3,000 fiit oo isku wareeg ah ee goobta teendhada. Goobta dab-demis kasta waa in lagu calaamadiyaa calaamado si cad u muuqda. Masaafada safarinta ugu badan ee dab-demis kasta oo teendhada ku dhex jira waa inuu ahaadaa 50 fiit (21 SFC Section 3107.9)
6. Baabuurga teendhada ku jira waa in haamaha shidaalka la faaruqiyoo oo filooyinka baytariga la jaray - eeg shuruudaha ruqsada buuxa ee gaarka ah. (21 Qaybta SFC 3107.15.1, 3107.15.2.1)
7. Ku dheji calaamadaha "NO SMOKING", kuwaas oo si sahal ah looga dhex arki karo teendhada/saqafka, oo dhaqangeliya xeerkan. (21 SFC Section 3107.3)
8. Dhulka, gudaha iyo dibaddaba, waa in laga ilaaliyaa qashinka guban kara. Qashin kasta waa in laga qaadaa oo lagu kaydiyaa hab la ogol yahay. (21 SFC Sections 3107.18 & 3107.19)
9. Waa inaysan jirin qalab ololi kara oo furan ama soo bandhiga loo ogolyahay teendhada gudaheeda iyada oo aan oggolaansho hore laga helin Fire Prevention Division. (21 SFC Section 3107.4)
10. Dhibcaha darbiyada iyo korka teendhada waa inay ahaadaan walxo ololka celinaya. (21 SFC Section 3104.2)
11. Xaalad kasta oo aan la saadaalinin oo keeni karta khatar dab ahaaneed, ama sababi karta fidinta degdega ah, ama dib u dhigi karta ama carqaladaynaya ka bixista degdega ah ee teendhada, taas oo aan lagu daboolin ogolaanshan, waa in isla markiiba la baabi'iyyaa ama la saxaa. (21 SFC Section 105.3)
12. Qalabka kuleyliyaha ee korontada ku shaqeeya oo kaliya ayaa loo ogol yahay gudaha teendhada. Dhamaan aaladaha kale ee kulaylinta (sida propane, naافتادا iyo kerosene lagu shiday) waa inay ka baxsan yihiin teendhada oo ay u baahan yihiin ogolaansho gaar ah oo ay bixiso Seattle Fire Department. (21 SFC Sections 105.3 & 105.5)
13. Kuleyliyeasha korantada iyo qalabka kale ee korantada waa in ay liis gareeyaan oo ay ansixiyaan UL, FM ama wakaalado kale oo tijaabinta oo lagu xiriiriyo meel koronto oo la ansixiyay. (21 SFC Section 603.9)
14. Waayar galinta waa in si cad loo calaamadiyaa si looga fogaado inay noqoto khatar soo jiidasho leh (21 SFC Section 105.3)
15. Si loo ansaxiyo, ruqsadan iyo lifaaqyadan waa in lagu dhejiyaa meel u dhow degenaanshaha/hawlaha. (21 SFC Section 105.3.5)
16. Kuraasta dabacsan, kuraas laablaaban ama fadhi la mid ah, oo ka tiro badan 200, waa in la isku xidhaa iyada oo kooxo ah saddex ama ka badan. (21 SFC Section 1030.15)
17. Dhukumiinti hadda ka dib loo tixraacayo "Letter of Structural Stability (LOSS)" waa in la bixiyaa marka la codsado oggolaanshan (21 SFC Section 3103.6 and 3103.9)
18. Teendhooyinka ku meel-gaarka ah waa in aan la degin xiliyada barafka ama barafku urursan yihiin ilaa loogu talagalay in si buuxda loo raro qaab-dhismeed sida Xeerka Dhismaha Seattle. (21 SFC Section 3103.9)